
Green Infrastructure and Low Impact Development Evaluation and Implementation Plan

Final Report

Prepared for the Town of Ogden, NY

November 2011



STEARNS & WHEELER
CLIENTS | PEOPLE | PERFORMANCE



PROJECT MANAGER

Genesee/Finger Lakes Regional Planning Council

50 West Main Street, Suite 8107

Rochester, NY 14614

www.gflrpc.org

Brian C. Slack, AICP – Senior Planner

Jayne Breschard – Senior Planner

David S. Zorn – Executive Director

PROJECT CONSULTANT

Stearns and Wheler GHD

One Remington Park Drive

Cazenovia, NY 13035

Gregory S. Liberman, CPESC – Environmental Designer

John J. Lagorga, P.E., BCEE – Senior Project Manager, Infrastructure

Liz Moran, Ph.D., EcoLogic, LLC

This project has been funded by the American Recovery and Reinvestment Act with support from the New York State Department of Environmental Conservation and New York State Economic Recovery and Reinvestment Cabinet. For more information, please visit: www.recovery.gov, www.dec.ny.gov or www.recovery.ny.gov.



RECOVERY.GOV



NYWORKS

Project Background

An Overview of the Green Infrastructure and Low Impact Development Planning Project

In 2009 Genesee/Finger Lakes Regional Planning Council was awarded funding for regional comprehensive water quality management planning activities as described in Section 604(b) of the Clean Water Act. This project was funded from the New York State Department of Environmental Conservation's appropriations from the American Recovery and Reinvestment Act (ARRA). A full description of 604(b) ARRA awards and project requirements can be found on the NYSDEC website at the following address: <http://www.dec.ny.gov/lands/58603.html>.

The purpose of this *Genesee-Finger Lakes Green Infrastructure and Low Impact Development Evaluation* project was to produce a reliable inventory and assessment of potential stormwater "green infrastructure" retrofit projects within selected municipalities and to provide an assessment of the local regulatory framework to ensure compatibility with Low Impact Development (LID) practices. The following white paper summarizes the results of this inventory and assessment process.

This information can be used to help plan for local stormwater needs, meet existing stormwater regulations or water quality goals, and apply for implementation funds if and when they become available. To date, several municipalities – including the Town of Parma and the Villages of LeRoy and Penn Yan – have used the findings of this study to apply for funds made available through the NYS Environmental Facilities Corporation Green Innovation Grants program.¹

A total of 9 municipalities in the Genesee-Finger Lakes region were selected to participate in this project. Project staff conducted field visits in these municipalities in the spring and summer of 2011 to identify and assess potential locations for green infrastructure stormwater facilities utilizing a standard approach created by the Center for Watershed Protection (CWP).² During that same time staff also assessed the body of local regulations within each project municipality utilizing the Center for Watershed Protection's Code and Ordinance Worksheet.³

This paper includes a brief explanation of the concepts of stormwater green infrastructure and Low Impact Development followed by a summary of the findings of this project relevant to the Town of Ogden. These findings are intended for use by the Town of Ogden and other project municipalities as they see fit.

Stormwater Retrofits
are stormwater management practices in locations where stormwater controls did not previously exist or were ineffective.

Green Infrastructure
management approaches and technologies infiltrate, evapotranspire, capture and reuse stormwater to maintain or restore natural hydrologies.

¹ NYSEFC Green Grants. <http://www.nysefc.org/GreenGrants.aspx>

² CWP's "Retrofit Reconnaissance Investigation" forms identified in Manual 3 of CWP's *Urban Subwatershed Restoration Manual Series* <http://www.cwp.org/categoryblog/92-urban-subwatershed-restoration-manual-series.html>

³ CWP's "Codes and Ordinances Worksheet," available online at the following address http://www.cwp.org/documents/cat_view/77-better-site-design-publications.html

Project Background

An Overview of the Green Infrastructure and Low Impact Development Planning Project



What is Stormwater Green Infrastructure?

Why It Matters: An Excerpt from Managing Wet Weather with Green Infrastructure – US EPA¹

Existing development, especially in urbanized and urbanizing areas, is responsible for currently degraded water quality and stream conditions. Changes in land cover and the increased imperviousness of the urban environment have resulted in larger volumes of runoff traveling at faster velocities. This has caused serious streambank erosion and has compromised aquatic habitat. Many of these areas were developed without adequate stormwater controls and must be addressed if urban streams are to be restored and water quality is to be improved.

Retrofits to stormwater infrastructure will be necessary to reduce runoff and pollution, but the capital investment is daunting. Upgrades to stormwater and combined sewer systems, like other utilities, are capital-intensive projects. The EPA has estimated that current wastewater infrastructure requires an investment in excess of \$200 billion, with \$10 billion needed for stormwater management and \$60 billion needed for combined sewer overflow (CSO) correction. While this needed investment presents a significant economic burden, it also presents an opportunity to re-evaluate the most efficient way to invest in infrastructure and environmental programs.

Using green infrastructure for urban stormwater retrofits can reduce stormwater pollution while simultaneously reducing the burden and demand on existing infrastructure. However, water quality and quantity benefits are not the only advantages green infrastructure has to offer. Green infrastructure enhances communities by bringing aspects of the natural environment into inhabited space. Trees provide shade, act as wind breaks and noise barriers, and improve air quality. In many instances, green infrastructure has been found to be less costly than or cost-competitive with traditional infrastructure. Green infrastructure provides additional environmental and economic benefits for the investment rather than traditional stormwater management approaches that literally bury the investments out of sight. The additional benefits that green infrastructure provides include:

- Green infrastructure effectively counteracts urban heat island by substituting soils and vegetation for hard, heat absorbing materials common in urban areas, creating shade, and emitting water vapor.
- Green roofs and other vegetation incorporated on and around buildings, help shade and insulate buildings from wide temperature swings, decreasing the energy needed for heating and cooling.
- Green infrastructure improves air quality as vegetation absorbs gaseous air pollutants and absorbs particulates.
- Research indicates that property values increase when street trees are planted and vacant lots are greened, providing private benefits to homeowners, increased property tax revenue, and more livable communities.

The distributed green infrastructure network is designed to limit the conversion of precipitation to runoff by capturing rainwater where it falls, managing stormwater at the surface, and maximizing soil and vegetation contact during treatment. This combination allows green infrastructure to reduce stormwater volumes, peak flow rates, and pollutant concentrations.

Stormwater green infrastructure facilities work through a combination of

- Encouraging the infiltration of stormwater into the ground
- Encouraging evapotranspiration of stormwater through increased vegetation, and
- Capture and use

What is Stormwater Green Infrastructure?

Why It Matters

Green infrastructure is implemented through a variety of specific applications, including:

- Bioretention and Vegetated Swales
- Porous or Pervious Concrete and Asphalt and Permeable Block Pavers
- Rain Gardens
- Trees and Expanded Tree Boxes
- Reforestation and Canopy Restoration
- “Green Streets” which incorporate many of the above practices into one linear streetscape
- Green Roofs, Cisterns and Rain Barrels installed in individual homes and businesses

What is Low Impact Development (LID)?

Green infrastructure also includes better construction and design practices within new residential and commercial developments. This concept is explained through the comprehensive approach to development known as *Low Impact Development*.

Low Impact Development (LID) is an ecologically-friendly approach to site development and storm water management that aims to mitigate development impacts to land, water, and air. The approach emphasizes the integration of site design and planning techniques that conserve natural systems and hydrologic functions on a site. The practice has been successfully integrated into many municipal development codes and storm water management ordinances throughout the United States. Specifically, LID aims to:

- Preserve open space and minimize land disturbance
- Protect natural systems and processes (drainage ways, vegetation, soils, sensitive areas)
- Reexamine the use and sizing of traditional site infrastructure (lots, streets, curbs, gutters, sidewalks) and customize site design to each site (known as ***Better Site Design***)
- Incorporate natural site elements (wetlands, stream corridors, mature forests) as design elements
- Decentralize and micromanage storm water at its source⁴

Better site design (BSD) is a means of implementing Low Impact Development. BSD incorporates non-structural and natural approaches to new and redevelopment projects to reduce effects on watersheds by ***conserving natural areas, reducing impervious cover*** and ***better integrating stormwater treatment***.

Conventional design can be viewed as the style of suburban development that has evolved during the past 50 years and generally involves larger lot development, clearing and grading of significant portions of a site, wider streets and larger cul-de-sacs, enclosed drainage systems for stormwater conveyance and large “hole-in-the-ground” detention basins. The aim of better site design is to reduce the environmental “footprint” of the site while retaining and enhancing the owner/developer’s purpose and vision for the site.⁵



For further information regarding the concepts mentioned above, visit the *G/FLRPC Green Infrastructure Resource Guide*, available online at <http://www.gflrpc.org/GreenInfrastructureResourceGuide.htm>

⁴ Summary on LID taken from the Low Impact Development Center’s pamphlet *Municipal Guide to Low Impact Development*. http://www.lowimpactdevelopment.org/lid%20articles/Municipal_LID.pdf

⁵ Summary on BSD taken from the NYSDEC Division of Water’s guidebook *Better Site Design*. http://www.dec.ny.gov/docs/water_pdf/bsdcomplete.pdf

Project Findings

This paper separates the findings for the Town of Ogden into two sections: *Stormwater Retrofit Reconnaissance Results* and *Code and Ordinance Assessment Results*.

Stormwater Retrofit Reconnaissance Results

The following are the results of an assessment of potential green infrastructure demonstration and/or retrofit projects found within Ogden. This list is not comprehensive in scope; the number of potential retrofit projects that can be found within any given municipality are virtually limitless. This assessment focused on specific stormwater goals that were discussed in advance, including:

- Reduction of pollutants to Northrup Creek, which feeds Greece Ponds, a 303(d) waterbody
- Continued compliance with Phase II regulations
- Local demonstration projects to educate Highway Dept. staff and the public on the design and function of green infrastructure stormwater facilities

A total of 25 potential projects were identified across the 9 project municipalities; two sites were initially identified in Ogden which was later narrowed down to one site.

The following locations were identified in the initial consultation between G/FLRPC staff and Town staff:

1. Ogden Town Highway Garage
2. Maida Drive

After sites were identified, the project consultant – Stearns and Wheler GHD – performed the majority of technical analysis associated with green infrastructure retrofit design.

GHD conducted rapid field reconnaissance for each site listed above in order to gauge feasibility and then develop conceptual retrofit design sketches for the most feasible sites. In addition, GHD evaluated likely construction costs and the potential water quality benefits of each project, as well as other factors which may impact decision-making relative to the eventual construction of these facilities. Other factors include constructability, proximity to impaired waters, and other benefits, such as public education, diverting stormwater from municipal/private infrastructure, wildlife habitat, and flood storage capacity.

The assessment of individual sites includes a basic overview of site conditions, probable construction cost estimates, and conceptual plans of potential green infrastructure facilities.

Project Findings

Stormwater Retrofit Reconnaissance Results

Each proposed retrofit project was assessed for water quality and other benefits. A total of six criteria were used to assess and evaluate these projects:

1. Nutrient Removal
2. Total Suspended Solids (TSS) Removal
3. Nutrient Export to Impaired Waters (TP – Total Phosphorous; TN – Total Nitrogen)
4. Constructability/Maintenance
5. Probable Construction Costs
6. Other Unique Benefits

The key criteria are based on improvements to water quality and are similar to factors outlined in the U.S. Army Corps of Engineering, Wetland Functions and Values Assessments (1999). These include Nutrient Removal, Total Suspended Solids (TSS) Removal, and Nutrient Export to Impaired Waters. The other factors affect the potential implementation of these practices and include Constructability, Probable Construction Costs, and Other Unique Benefits.

The following is a description of the criteria used in this assessment.

1. Nutrient Removal. Based on Simple Method assessment of existing conditions (land-use, acreage, and rainfall) and treatment practice removal rates, as presented in Table A.4 of the NYS Stormwater Management Design Manual resulting in an **estimated lbs/year of nutrients removed**. It should be noted that these data were developed from conceptual sketches prepared using field measurements and are intended for planning purposes only.

Based on the assessment of the conceptual designs, each site was given a relative score of High, Moderate, or Low according to the following:

- High – TP removed was greater than 2.0 lbs/year
- Moderate – TP removed ranged from 1.0 – 1.9 lbs/year
- Low – TP removed was less than 1.0 lbs/year

2. TSS Removal. Based on Simple Method assessment of existing conditions (land-use, acreage, and rainfall) and treatment practice removal rates outlined in Table A4 of the NYS Stormwater Management Design Manual resulting in an **estimated lbs/year of TSS removed**. It should be noted that these data were developed from conceptual sketches prepared using field measurements and are intended for planning purposed only.

Based on the assessment of the conceptual designs, each site was given a relative TSS removal score of High, Moderate, or Low according to the following:

- High – TSS removed was greater than 500 lbs/year
- Moderate – TP removed ranged from 100 to 499 lbs/year
- Low – TP removed was less than 100 lbs/year

3. Nutrient Export to Impaired Waters. Evaluated a project site's proximity to an **impaired or sensitive water body**. Impaired waters were determined based on a review of the NYS 303 (d) and 305 (b) lists. For this project, impaired waters include the Rochester Embayment of Lake Ontario and Greece

Project Findings

Stormwater Retrofit Reconnaissance Results

Ponds (Buck Pond, Long Pond and Cranberry Pond). Northrup Creek is a tributary to these waterbodies. For this project, sensitive water bodies include **NYSDEC regulated wetlands**.

Each site was given a relative score of High, Moderate, or Low based on proximity to impaired waters.

- High – Direct discharge to impaired waters
- Moderate – Potential discharge to impaired water or direct discharge to tributary of impaired waters
- Low – No direct connection to impaired waters

4. Constructability/Maintenance. Evaluated for the potential “constructability” for each retrofit project, as well as the anticipated long-term operations and maintenance requirements. For example, a small rain garden was considered to have somewhat simple construction (**High**), whereas a large wetland complex was considered to require engineering design, permitting, and long period of construction (**Low**). Each site was given a relative score of High, Moderate, or Low based on our assessment of the potential upfront engineering and permitting efforts, as well as anticipated complexity of construction and need for the long-term maintenance.

- High – Required significant engineering/permitting, as well as complex construction and significant O&M
- Moderate – Limited upfront engineering or permitting with some construction complexities, such as limited space
- Low – Little anticipated need for upfront engineering/permitting, simple construction with limited long-term O&M

5. Probable Construction Costs. Established unit costs for each type of retrofit practice based on published sources, such as the NYS Stormwater Management Design Manual (2008 and 2010). The probable construction cost was calculated by multiplying the unit costs by the conceptual size of the practice. Some minor variation of unit costs were taken into account based on project complexities. Probable construction costs were used to develop Cost per Pound of Nutrient (TN and TP) Removed and Cost per Pound of TSS Removed. It should be noted that probable construction costs were developed based on conceptual sketches and may fluctuate based on final site specific circumstances or other various factors. These costs are intended for planning purpose only.

The cost per pound of TN and TP removed per year varied based on project size and type. For the projects within this study, relative scores of High, Moderate, and Low were derived based on the ranges of costs as follows:

- High – Cost per pound of total nutrients (TN and TP) is less than \$5,000
- Moderate – Cost per pound of total nutrients (TN and TP) is between \$5,000 and \$15,000
- Low – Cost per pound of total nutrients (TN and TP) is greater than \$15,000

6. Other Unique Benefits. Local and regional water quality is at the core of this project. However, many of the proposed retrofit projects result in additional benefits beyond water quality improvements. These include opportunities for public education, diversion of stormwater from municipal/private infrastructure, enhanced wildlife habitat, and flood storage capacity.

These other benefits were given relative scores of High, Moderate, and Low based on the following:

- High – Direct potential for other benefits, such as sites located within parks

Project Findings

Stormwater Retrofit Reconnaissance Results

- Moderate – Potential for other benefits, such as improved wildlife habitat or improved aesthetics
- Low – Limited or no potential for other benefits beyond water quality improvements

Project Findings

Conceptual Stormwater Retrofit Plans

Each stormwater retrofit design is documented on the attached *Conceptual Stormwater Retrofit Plans*. In addition, the benefits of each project are documented in the attached *Benefit Assessment Worksheet*.

In addition to the plans and worksheets, the retrofit projects were qualitatively ranked relative to one another, and this information is attached in the *Qualitative Assessment Table* (QAT). It is important to note that the scoring in the QAT is relative to the retrofit projects in this assessment only. Further, these retrofit projects, regardless of score, all provide water quality and other unique benefits.

GHD has developed the conceptual design plans and has assessed each site based upon the above reference criteria. Based on our review, it appears the proposed projects can be divided into three categories based on type of stormwater practice: Filtration Practices (bioretention, rain gardens, bioswales), Stabilization (outlet protection, bank stabilization) and Stormwater Ponds/Wetlands. These types of practices vary significantly in terms of construction costs, engineering requirements, and water quality improvements. While each of these projects has a direct water quality permitting benefit and should be evaluated as part each municipality's long-term plan, some general distinctions about each group can be made.

It appears that filtration practices generally have the lowest cost per pound of nutrients removed with the cost per pound of nutrients (TN and TP) removed per year combined generally less than \$3,800. The stabilization projects appear to be the most cost effective at reducing TSS with the cost per pound of TSS removed typically below \$10. These stabilization practices also appear effective at preventing nutrient loading due to the significant level of anticipated soil stabilization. Also, large-scale stabilization project can be an efficient method of nutrient removal. While stormwater ponds and wetland do not have the lowest cost per pound of nutrients or TSS removed, these practices do allow for the most quantity of nutrient and TSS to be removed annually. For example, the least efficient stormwater wetland in this study is anticipated to remove more than 3 lbs of TP and 18 lbs of TN per year. This is far greater than the majority of the smaller scale filtration practices and should be considered when reviewing the entirety of these projects. Similarly, smaller projects, such as rain gardens around public buildings, have an aesthetic benefit and can be used to educate and engage the public.

Two initial sites were narrowed down to the following high-value site:

- 1. Maida Drive Stormwater Easement.** The Town of Ogden has a stormwater easement over multiple acres adjacent to Northrup Creek directly south of the vacant Ogden Wastewater Treatment Plant. This area is comprised of a wooded and open meadow areas. A small drainage ditch transects this easement as well. This portion of the Creek is largely untreated runoff from a predominantly developed (paved) upstream watershed.

The purpose of the retrofit is to construct a stormwater wetland system adjacent to the Creek to provide low-flow water quality treatment for a portion of diverted flow from Northrup Creek. The system would require a low flow diversion from the west bank of Northrup Creek. This could be as simple as a 12-inch diameter inlet pipe set at a low flow elevation near bankfull elevation. Flow from the system would meander through a constructed two-acre wetland allowing for biological uptake of nutrients and sediment deposition. A controlled outlet structure would be located at the end of wetland system discharging back to the creek. In addition to water quality improvement, the wetland system would provide opportunity for habitat and potential flood storage.



Ogden – Maida Drive Wetland

Benefit Assessment Worksheet

The purpose of the retrofit is to construct a stormwater wetland system adjacent to Northrup Creek to provide water quality treatment for a portion of diverted flow from Northrup Creek. The system would require a low flow diversion, meandering wetland complex and controlled outlet structure discharging flow back into the Creek. In addition to water quality, the wetland system would provide opportunity for habitat and potential flood storage.




Nutrient Removal

Nutrient loading based on a percentage of watershed, correlated to size of low-flow diversion. Baseline TN and TP are approximately 63.0 and 6.3 lbs/year, respectively. Anticipating 30 percent and 50 percent removal rate based on a stormwater wetland system, the **estimated pounds of TN and TP removed per year is 19.0 and 3.0**, respectively.



TSS Removal

TSS loading based on a percentage of watershed correlated to size of low-flow diversion. Baseline TSS for this site is approximately 860 lbs/year. Anticipating 80 percent removal rate based on a wetland system, the **estimated pounds of TSS removed per year is 685**.



Nutrient Export To Impaired Waters

The project site is directly adjacent to Northrup Creek. While this stream has been stressed from development, it is not listed as an impaired water; it does, however, drain to the Greece Ponds (Long Pond specifically), which are listed as an impaired water.



Constructability/Maintenance

The construction of the stormwater wetland at Maida Drive will require significant engineering and permitting prior to construction. Also, the project requires flow-diversions, structures, and extensive earthwork. Because of this, the constructability for this practice is considered **Low**. In addition, the project is likely to require significant long-term maintenance and monitoring.



Probable Construction Costs

A unit value of \$10 per square foot for a stormwater wetland within the an open area was multiplied by the conceptual size of the retrofit practice (80,000 square feet) for a probable construction cost of \$800,000. This results in an anticipated **cost per Pound of nutrients (TN and TP) removed of \$36,000 and Cost per Pound of TSS removed of \$1,100**.



Other Benefits

In addition to water quality improvement, this project could also provide for **enhanced wildlife habitat and additional flood storage**.



Rev. A

[illegible]

Note: original scale drawings have been provided to staff within each project municipality. Contact Stearns and Wheeler GHD for more information.

Project Findings

Code and Ordinances Worksheet Findings

Each project municipality's body of local laws and ordinances was reviewed utilizing the Center for Watershed Protection's (CWP) *Code and Ordinance Worksheet*. On average, most municipalities scored between 60 and 70 points out of 100 points, which denotes that opportunities exist to improve development rules in order to protect local aquatic resources in addition to the benefit of creating a site planning roundtable. Such a roundtable is described as a consensus process to encourage board members to make better choices in the design of their community. The primary tasks of a local roundtable are to systematically review existing development rules in the context of the model development principles, and then determine if changes can or should be made to the rules.

Genesee/Finger Lakes Regional Planning Council (G/FLRPC) collaborated with other regional entities, including the Stormwater Coalition of Monroe County, to identify the best methodology to use for this analysis. The CWP's *Code and Ordinance Worksheet* was selected due to its focus on the specific issue of local laws – namely, zoning, site plan review and subdivision law. The 77 site planning questions posed in the *Code and Ordinance Worksheet* are awarded specific points if the municipality's local law compares favorably with the benchmark.

Based on the 22 sections of the *Code and Ordinance Worksheet*, three major documents were necessary to fully complete it: the municipality's zoning ordinance, subdivision code, and design and construction criteria. In some cases, if the municipality is a regulated Municipal Separate Storm Sewer System (MS4), an erosion and sediment control ordinance and/or stormwater management ordinance was also reviewed.

The process established to complete the *Code and Ordinance Worksheet* was composed of two phases: the first phase allowed staff at G/FLRPC to complete the worksheet using the municipality's applicable local laws. The reviewer then sent this draft to the municipality's designated point-of-contact. The municipality then had the opportunity to review this draft before a meeting was set-up between the reviewer and the municipality. The dialogue between the reviewer and municipality was valuable in that many inconsistencies were found throughout the *Code and Ordinance Worksheet*.

The *Code and Ordinance Worksheet* clearly states that the reviewer "must identify the local, state, and federal authorities that actually administer or enforce the development rules within your community." Municipal staff that interact daily with these development rules are significantly more aware of these rules than the reviewer. Municipal staff readily pointed out to the reviewer where inconsistencies could be found. For example:

- Dead-end fire apparatus access roads in excess of 150 feet must provide width and turnaround provisions in accordance with Table D103.4 of the New York State Fire Code. In this case, a cul-de-sac must have a 96-foot-diameter. In Section 4: Cul-de-Sacs, the *Code and Ordinance Worksheet* awards 3 points for a radius less than 35 feet and 1 point for an answer between 36 feet and 45 feet. Neither benchmark corresponds with the 48-foot-radius minimum requirement according to D103.4: Dead ends of the New York State Fire Code.
- According to 511.2.1: Dimensions of the New York State Fire Code, driveways must provide a minimum unobstructed width of 12 feet. Section 14: Driveways of the *Code and Ordinance Worksheet* awards one point only if the answer is below 9 feet.
- Fire apparatus access roads must also have an unobstructed width of not less than 20 feet, except for approved security gates, according to 503.2.1: Dimensions. Therefore, the benchmark set

Project Findings

Code and Ordinances Worksheet Findings

for 18 to 22 feet for Section 1: Street Width of the *Code and Ordinance Worksheet* does not necessarily comply.

Another area of discrepancy is Section 13: Sidewalks of the *Code and Ordinance Worksheet* with the Americans with Disabilities Act (ADA). State and local government facilities must follow the 2010 Standards for Accessible Design as of March 15, 2012. Before that date, the 1991 Standards or the Uniform Federal Accessibility Standards (UFAS) were used for projects.

An accessible route is defined in Chapter 4 of the 2010 Standards as one or more of the following components: a walking surface with a running slope not steeper than 1:20, doorways, ramps, curb ramps excluding the flared sides, elevators, and platform lifts. The clear width of walking surfaces can be 36 inches. However, if a clear width less than 60 inches is provided, passing spaces must be made available at intervals of 200 feet. Passing spaces can be either 60 inches minimum by 60 inches or an intersection of two walking surfaces providing a T-shaped space where the base and arms of the T-shaped space extend 48 inches beyond the intersection. The 1991 Standards states the minimum clear width for single wheelchair passage is 32 inches at a point and 36 inches continuous with a 60 inch minimum width for two wheelchairs to pass. The minimum clear width of an accessible route as defined by UFAS is 36 inches with passing spaces at reasonable intervals not to exceed 200 feet if the accessible route is less than 60 inches in width. The *Code and Ordinance Worksheet* awards two points for a minimum width of 4 feet or less allowed in the community.

One final discrepancy in the *Code and Ordinance Worksheet* can be found in Section 8: Parking Lots regarding the minimum stall width and length for a standard parking space. The *Manual on Uniform Traffic Control Devices* (MUTCD) is published and has been administered by the Federal Highway Administration (FHWA) since 1971. The manual is a compilation of national standards for traffic control devices installed and maintained on all public streets, highways, bikeways, and private roads open to public traffic. It is updated periodically to address changing transportation needs in the nation. The MUTCD became effective in New York State on January 15, 2010 with a NYS Supplement adopted on March 16, 2010. In this manual, a typical parking space is recommended to be 8 feet wide by 22 to 26 feet in length and an end space as 8 feet by 20 feet. The *Code and Ordinance Worksheet* awards one point for a stall width less than 9 feet and one point for a stall length less than 18 feet.

Overall, most municipalities scored between 60 and 70 points out of a total 100. Several municipalities scored below 60 points, which states that “serious reform of the development rules is needed.” A score of 90 to 100 states that the community is “a real leader in protecting streams, lakes, and estuaries.” A score of 60 to 69 and 70 to 79 basically states the community doesn’t have adequate development rules to protect local aquatic resources and that significant opportunities exist. There were three questions that none of the municipalities scored any points on:

- At higher densities are parking lanes allowed to serve as traffic lanes (i.e., queuing streets). (Section 1: Street Width, 3 points available)
- If mass transit is provided nearby, is the parking ratio reduced? (Section 7: Parking Codes, 1 point available)
- Are there any incentives to developers to provide parking within garages rather than surface parking lots? (Section 9: Structured Parking, 1 point available)

Project Findings

Code and Ordinances Worksheet Findings

As these questions seem “non-applicable,” they should be considered for removal from the *Code and Ordinance Worksheet* and total maximum points awarded to each municipality.

Another generalization about the *Code and Ordinance Worksheet* applies when dealing with a historic community versus contemporary ones. The Village of Spencerport, Le Roy, Penn Yan, Churchville and Dryden experienced growth and development much earlier than most towns participating in the local law analysis. A good deal of the land available in these villages has already been built upon; thus, street widths and lengths and lot setbacks and frontages have already been determined. These villages were also developed long before zoning and other standards and ordinances existed. The Towns of Ogden, Parma, Walworth and Webster are currently experiencing population growth due to suburban expansion. There are more opportunities with current regulatory processes to encourage low-impact design and development in these municipalities. Hence, the *Code and Ordinance Worksheet* may provide more opportunities for growing communities to score higher with new construction as opposed to historic communities with existing footprints. In this case, a scoring methodology that considers more retrofit-friendly frameworks, regulatory structures, and incentive programs is recommended in future reviews for historic communities.

Finally, each municipality discovered different strengths, weaknesses, and areas of opportunity through the *Code and Ordinance Worksheet* process. They are as follows:

Town of Ogden

Total: 60

Strengths:

- Section 11: Open Space Design
- Section 15: Open Space Management
- Section 17: Buffer Systems
- Section 20: Tree Conservation
- Section 21: Land Conservation Incentives
- Section 22: Stormwater Outfalls

Weaknesses:

- Section 6: Parking Ratios
- Section 8: Parking Lots
- Section 12: Setbacks and Frontages
- Section 18: Buffer Maintenance

Areas of Opportunity

- The volume of stormwater generated at parking lots could be reduced if the Town of Ogden required landscaping for off-street parking areas and reduced parking requirements to allow smaller spaces. Bioretention facilities, dry swales, perimeter sand filters, and filter strips are types of landscaped areas that provide stormwater management. These techniques could also enhance the appearance of parking lots and visually separate land uses or development.

Project Findings

Code and Ordinances Worksheet Findings

- Parking codes could also be amended to require that a fixed percentage (i.e. 15 to 30%) of all parking stalls be dedicated for compact cars. *Town of Ogden Comprehensive Plan* (February 2003) calls for the design and construction of pedestrian safety and convenience into all parking areas in addition to attractiveness of commercial areas through adequate landscaping and property maintenance in “Policy Area: Design and Development.”

Code and Ordinance Worksheets

The following pages contain the summarized results of the CWP Code and Ordinance Worksheets. Those results are organized into the following major and minor categories:

- **Residential Streets and Parking Lots**
 - Street width and length
 - Right of way width
 - Cul-de-sacs
 - Vegetated open channels
 - Parking ratios
 - Structured parking
 - Parking codes
 - Parking lots
 - Parking lot runoff
- **Lot Development**
 - Open space design
 - Setbacks and frontages
 - Sidewalks
 - Driveways
 - Open space management
 - Rooftop runoff
- **Conservation of Natural Areas**
 - Buffer systems
 - Buffer maintenance
 - Clearing and grading
 - Tree conservation
 - Land conservation
 - Stormwater outfalls

Areas found to be deficient with regard to stormwater green infrastructure or LID have been checked (☑) as “to be revised.”

Where available, online resources have been cited under the “Notes” section and provide more information relevant to the category or subcategory. Interested readers should visit these resources to learn more about the issue and how their municipality can improve its local codes and operations therein.

Project Findings

Code and Ordinances Worksheet Findings

RESIDENTIAL STREETS AND PARKING LOTS

1. and 2. Street Width and Length	<p>Is the minimum pavement width for low traffic residential streets (<500 average daily trips) between 18-22 ft.? <u>20</u> ft. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Section: <u>Town Design Criteria and Construction Standards</u> <input type="checkbox"/> No Standard <i>Action:</i> <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 5 out of 8 points
	<p>Can parking lanes serve as traffic lanes in higher density areas? <input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	
	<p>Are alternatives to minimize street length allowed where appropriate (i.e. cluster developments, around cul-de-sacs, etc.)? <input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed <i>Action:</i> <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	
3. Right-of-Way Width	<p>Is minimum ROW widths less than 45 ft. for a residential street? <u>60</u> ft. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>Town Design Criteria and Construction Standards</u> <input type="checkbox"/> No Standard <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: <i>Right-of-Way Improvements Manual</i>, City of Seattle, Washington. Available at: http://www.seattle.gov/transportation/rowmanual.</p>	Score: 0 out of 4 points
	<p>Can utilities be placed below the paved section of the ROW? <input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	

Project Findings

Code and Ordinances Worksheet Findings

4. Cul-de-Sacs	<p>Is the minimum required radius for cul-de-sacs less than 35 ft.? <u>50</u> ft.</p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>Town Design Criteria and Construction Standards</u> <input type="checkbox"/> No Standard</p> <p style="text-align: right;">Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: <i>Impervious Surface Reduction: Cul-de-Sac Design</i>, prepared for the Metropolitan Council by Barr Engineering Company. Available at: http://www.barr.com/clientre/Archives/BMPs/BMPfiles/03RPPImpCuldeSac.pdf.</p> <hr/> <p>Are landscaped or bioretention islands allowed in the center of cul-de-sacs?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p> <hr/> <p>Are alternatives to cul-de-sacs such as “hammerheads” allowed for permanent turnarounds?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 2 out of 5 points
5. Vegetated Open Channels	<p>Are curbs and gutters required for most residential streets?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>167-6</u> <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p> <hr/> <p>Are modified curb or gutter systems such as vegetated swales or curb cuts with rain gardens allowed to provide for stormwater infiltration and evaporation?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>167-22</u> <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 2 out of 4 points

Project Findings

Code and Ordinances Worksheet Findings

6. Parking Ratios	<p>Are the minimum required number of parking spaces less than: 3 spaces per 1,000 sq. ft. for professional office building? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>210-75</u> <input type="checkbox"/> No Standard Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>4.5 spaces per sq. ft. for shopping centers? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>210-75</u> <input type="checkbox"/> No Standard Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>2 spaces per single family home? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Section: <u>210-75</u> <input type="checkbox"/> No Standard Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes: <i>Assessing Street and Parking Design Standards to Reduce Excess Impervious Cover in New Hampshire and Massachusetts</i>, U.S. Environmental Protection Agency. Available at: http://www.epa.gov/region1/npdes/stormwater/assets/pdfs/ImperviousAssessment.pdf.</p> <p>Are parking ratios expressed as both minimum and maximums? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No, minimum only <input type="checkbox"/> No, maximum only <input type="checkbox"/> No, Expressed as medians Section: <u>210-75</u> Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 1 out of 5 points
7. and 8. Structured Parking and Parking Codes	<p>Is the use of shared parking arrangements promoted? <input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-72 (A)</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p> <p>Are model shared parking agreements provided? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <input checked="" type="checkbox"/> Shared parking not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: <i>Model Shared Parking Agreements</i>, Town of Clinton: Recommended Model Development Principles for Protection of Natural Resources in the Hudson River Estuary Watershed. Available at: http://www.dec.ny.gov/docs/remediation_hudson_pdf/hrewbsdclin.pdf.</p> <p>Are parking requirements reduced for shared parking arrangements, structured parking, areas near mass transit, and special districts? <input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>	Score: 1 out of 5 points

Project Findings

Code and Ordinances Worksheet Findings

9. Parking Lots	<p>Are minimum stall dimensions for standard parking spaces 9 ft. x 18 ft. or less? <u>10</u> ft. x <u>20</u> ft.</p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>210-72: Parking areas (C)</u> <input type="checkbox"/> No Standard</p> <p>Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 2 out of 5 points												
	<p>Are smaller compact car stalls required for at least 30% of total parking spaces?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input checked="" type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: <i>Impervious Surface Reduction: Parking Lot Design</i>, Twin Cities Metropolitan Council. Available at: http://www.metrocouncil.org/environment/Water/bmp/CH3_RPPImpParking.pdf.</p>													
	<p>Can pervious materials be used for spillover parking areas?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-72</u> <input checked="" type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>													
10. Parking Lot Runoff	<p>Does a minimum percentage of parking lots need to be landscaped?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-49, 167-6, & 167-22</u> <input checked="" type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 4 out of 4 points												
	<p>Are bioretention islands or vegetated filter strips allowed within landscaped areas of parking lots?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-49, 167-6, & 167-22</u> <input checked="" type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>													
<p>Areas identified within Residential Streets and Parking Lots that are most in-line with Green Infrastructure principles:</p> <table border="0"> <tr> <td><input checked="" type="checkbox"/> Street Width Codes</td> <td><input type="checkbox"/> Parking Ratios</td> <td><input checked="" type="checkbox"/> Street Length</td> <td><input type="checkbox"/> Parking</td> </tr> <tr> <td><input type="checkbox"/> Row Width</td> <td><input type="checkbox"/> Parking Lots</td> <td><input type="checkbox"/> Cul-de-Sacs</td> <td><input type="checkbox"/> Structured Parking</td> </tr> <tr> <td><input type="checkbox"/> Vegetated Open Swales</td> <td><input checked="" type="checkbox"/> Parking Lot Runoff</td> <td></td> <td></td> </tr> </table>			<input checked="" type="checkbox"/> Street Width Codes	<input type="checkbox"/> Parking Ratios	<input checked="" type="checkbox"/> Street Length	<input type="checkbox"/> Parking	<input type="checkbox"/> Row Width	<input type="checkbox"/> Parking Lots	<input type="checkbox"/> Cul-de-Sacs	<input type="checkbox"/> Structured Parking	<input type="checkbox"/> Vegetated Open Swales	<input checked="" type="checkbox"/> Parking Lot Runoff		
<input checked="" type="checkbox"/> Street Width Codes	<input type="checkbox"/> Parking Ratios	<input checked="" type="checkbox"/> Street Length	<input type="checkbox"/> Parking											
<input type="checkbox"/> Row Width	<input type="checkbox"/> Parking Lots	<input type="checkbox"/> Cul-de-Sacs	<input type="checkbox"/> Structured Parking											
<input type="checkbox"/> Vegetated Open Swales	<input checked="" type="checkbox"/> Parking Lot Runoff													

Project Findings

Code and Ordinances Worksheet Findings

LOT DEVELOPMENT

11. Open Space Design	<p>Are conservation subdivisions and/or cluster developments allowed? <input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>173-22: Statutory provisions and Chapter 211: Incentive Zoning</u> <input type="checkbox"/> Site specific with Planning Board approval <input checked="" type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed <i>Action:</i> <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p> <p>Is water quality or land conservation a major goal? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Section: <u>211-2: Purpose and intent</u> <input type="checkbox"/> No Standard <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend impervious cover reduction as a major goal for intent and objectives.</p> <p>Are the application requirements for conservation subdivisions and/or cluster developments greater than for conventional developments? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>211-8: Criteria and procedure for approval</u> <input type="checkbox"/> No Standard <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p> <p>Are conservation subdivisions and/or cluster developments permitted by zoning without a public hearing? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>211-8: Criteria and procedure for approval</u> <input type="checkbox"/> No Standard <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 7 out of 8 points
12. Setbacks and Frontages	<p>Are irregular lot shapes (i.e. pie-shaped, flag lots) allowed? <input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-65</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed <i>Action:</i> <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p> <p>Are reductions in frontage distances allowed where appropriate to minimize street length? <input type="checkbox"/> Supportive language in code/ordinance Section: <u>210-27: Residential Transition District (G)</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: <i>Best Development Practices Guidebook</i>, Town of Franklin, Massachusetts. Available at: http://franklinma.virtualtownhall.net/Pages/FranklinMA_Planning/initiatives/bestdevelopment.pdf</p>	Score: 1 out of 6 points

Project Findings

Code and Ordinances Worksheet Findings

	<p>Are reductions in setback distances allowed where appropriate to minimize driveway lengths?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <u>210-27: Residential Transition District (G)</u></p> <p><input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance</p> <p><input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed</p> <p>Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	
13. Sidewalks	<p>Is the minimum required width for a sidewalk 4 ft. or less? <u>5</u> ft.</p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>Town Design Criteria and Construction Standards</u> <input type="checkbox"/> No Standard</p> <p>Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes: Continue to adhere to ADA Accessibility Guidelines.</p>	Score: 3 out of 6 points
	<p>Are sidewalks allowed on only one side of the street?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	
	<p>Are sidewalks sloped so that stormwater drains into the front yard as opposed to the street?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input checked="" type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	
	<p>Are alternative pedestrian pathway layouts allowed, rather than placement in road ROW?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input checked="" type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>	
14. Driveways	<p>Is the minimum driveway width 9 ft. or less (single lane) or 18 ft. (two lanes)? _____ ft. _____ ft.</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No Section: <input checked="" type="checkbox"/> No Standard</p> <p>Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: <i>Impervious Surface Reduction: Driveway Design</i>, prepared for the Metropolitan Council by Barr Engineering Company. Available at: http://www.barr.com/clientre/Archives/BMPs/BMPfiles/04RPPImpDriveway.pdf.</p>	Score: 4 out of 6 points
	<p>Are alternative materials and designs (i.e. porous pavers, two-track design, etc.) allowed?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>	

Project Findings

Code and Ordinances Worksheet Findings

	<p>Are shared driveways allowed?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>	
15. Open Space Management	<p>Does the community have requirements to allow homeowner associations or land trusts to manage open space?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>Chapters 5 & 211</u> <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 6 out of 6 points
	<p>Are conservation subdivisions and/or cluster developments located in close proximity required to consolidate their open space?</p> <p><input type="checkbox"/> Supportive language in code/ordinance Section: <input checked="" type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>	
	<p>Does a minimum percentage of open space need to remain in its natural condition?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-27 and 210-26</u> <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>	
	<p>Are uses for open space in residential developments defined?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-27 and 210-26</u> <input type="checkbox"/> Site specific with Planning Board approval</p> <p><input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications</p> <p><input type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes: Recommend inclusion with code/ordinance.</p>	

Project Findings

Code and Ordinances Worksheet Findings

16. Rooftop Runoff	Can rooftop runoff be discharged to yard areas? <input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>167-22</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Expressly allowed by design/construction specifications Notes:	<input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised	Score: 2 out of 4 points
	Is temporary ponding of stormwater allowed in front yards or on rooftops? <input type="checkbox"/> Supportive language in code/ordinance Section: <u>64-2: Prohibited acts (Drainage and Watercourses)</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Expressly allowed by design/construction specifications Notes:	<input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Typically not allowed Action: <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised	
Areas identified within Lot Development that are most in-line with Green Infrastructure principles:			
<div> <input checked="" type="checkbox"/> Open Space Design <input checked="" type="checkbox"/> Driveways <input type="checkbox"/> Setbacks and Frontages </div> <div> <input checked="" type="checkbox"/> Open Space Management <input type="checkbox"/> Sidewalks <input type="checkbox"/> Rooftop Runoff </div>			

Project Findings

Code and Ordinances Worksheet Findings

CONSERVATION OF NATURAL AREAS

17. Buffer Systems	<p>Is there an ordinance that provides for a river or stream buffer to protect water quality and habitat in streams and rivers? <u>120</u> ft.(minimum)</p> <p> <input type="checkbox"/> Supportive language in code/ordinance Section: <u>Town Design Criteria and Construction Standards</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised </p> <p>Notes: Recommend inclusion with code/ordinance.</p>	Score: 4 out of 4 points
18. Buffer Maintenance	<p>Does the river or stream buffer include lakes, wetlands, and coastal waters to protect water quality and habitats?</p> <p> <input type="checkbox"/> Supportive language in code/ordinance Section: <u>Town Design Criteria and Construction Standards</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised </p> <p>Notes: Recommend inclusion with code/ordinance.</p> <p>Does the ordinance require that the river or stream buffer remain in its natural condition?</p> <p> <input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised </p> <p>Notes:</p> <p>Are uses in the buffer area defined by the ordinance?</p> <p> <input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised </p> <p>Notes:</p> <p>Does the ordinance specify enforcement or education mechanisms?</p> <p> <input type="checkbox"/> Supportive language in code/ordinance Section: <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input checked="" type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised </p> <p>Notes:</p>	Score: 0 out of 4 points

Project Findings

Code and Ordinances Worksheet Findings

19. Clearing and Grading	<p>Are there clearing and grading requirements that limit the amount of exposed soil at residential development sites to reduce the potential for erosion and sedimentation?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>173-25 (B)</u> <input checked="" type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed <i>Action:</i> <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 2 out of 3 points
20. Tree Conservation	<p>Do reserve septic field areas need to be cleared of trees at the time of construction?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>173-25 (B)</u> <input checked="" type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Expressly allowed by design/construction specifications <input type="checkbox"/> Typically not allowed <i>Action:</i> <input type="checkbox"/> Leave as is <input checked="" type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 3 out of 3 points
21. Land Conservation Incentives	<p>Are certain trees or stands required to be preserved at residential development sites?</p> <p><input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>210-49 (B) 4, 210-39 (C), & 210-3 (E)</u> <input type="checkbox"/> Incentivized in code/ordinance <input checked="" type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Typically not allowed <input type="checkbox"/> Expressly allowed by design/construction specifications <i>Action:</i> <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</p> <p>Notes:</p>	Score: 4 out of 4 points

Project Findings

Code and Ordinances Worksheet Findings

	Is design flexibility permitted to meet regulatory or conservation restrictions? <input checked="" type="checkbox"/> Supportive language in code/ordinance Section: <u>Chapter 211: Incentive Zoning</u> <input type="checkbox"/> Site specific with Planning Board approval <input type="checkbox"/> Expressly allowed by design/construction specifications <div style="text-align: right;"><input checked="" type="checkbox"/> Incentivized in code/ordinance <input type="checkbox"/> Typically not allowed Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised</div> Notes:	
22. Stormwater Outfalls	Is stormwater required to be treated for quality before it is discharged? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Section: <u>Chapter 166-Article I</u> <input type="checkbox"/> No Standard Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised Notes:	Score: 6 out of 6 points
	Can stormwater be discharged directly into a jurisdictional wetland without pretreatment? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Section: <u>Chapter 166-Article I</u> <input type="checkbox"/> No Standard Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised Notes:	
	Are there effective design criteria for stormwater best management practices? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Section: <u>167-22: (A), (B) (1) (2)</u> <input type="checkbox"/> No Standard Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised Notes:	
	Does a floodplain management ordinance exist that restricts or prohibits development within the 100-year floodplain? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Section: <u>Chapter 82: Flood Damage Prevention</u> <input type="checkbox"/> No Standard Action: <input checked="" type="checkbox"/> Leave as is <input type="checkbox"/> To be revised Notes:	
Areas identified within Conservation of Natural Areas that are most in-line with Green Infrastructure principles: <div style="display: flex; justify-content: space-between;"> <div> <input checked="" type="checkbox"/> Buffer Systems <input checked="" type="checkbox"/> Land Conservation Incentives </div> <div> <input checked="" type="checkbox"/> Tree Conservation <input checked="" type="checkbox"/> Clearing and Grading </div> <div> <input type="checkbox"/> Buffer Maintenance <input checked="" type="checkbox"/> Stormwater Outfalls </div> </div>		

Total Score (out of 100): 59

Residential Streets and Parking Lots Score (out of 40): 17

Lot Development Score (out of 36): 23

Conservation of Natural Areas Score (out of 24): 19

Scoring (Out of 100 points)

90 – 100: Congratulations! Your community is a real leader in protecting streams, lakes, and estuaries. Keep up the good work!

80 – 89: Your local development rules are pretty good, but could use some tweaking in some areas.


Project Findings

Code and Ordinances Worksheet Findings

70 – 79:	Significant opportunities exist to improve your development rules. Consider creating a site planning roundtable.
60 – 69:	Development rules are inadequate to protect your local aquatic resources. A site planning roundtable would be very useful.
< 60:	Your development rules definitely are not environmentally friendly. Serious reform of the development rules is needed.

Summary of Green Infrastructure Sites

Qualitative Assessment Table

		Relative Assessment Scores (see Notes)						
		Nutrient Removal	TSS Removal	Proximity to Impaired Water	Constructability/Maintenance	Probable Construction Costs	Other Unique Benefits	Total
Site	Practice							
Parma Town Hall	Bioswale (Water Qual Swale)	5	5	5	3	5	5	28
Parma Town Hall	Porous Paving	5	5	5	2	5	5	27
Parma Town Hall	Stabilization (Outlet)	1	5	5	5	5	5	26
Webster Town Hall	Stabilization (Bank)	5	5	3	2	5	5	25
Walworth Town Hall	Stormwater Wetlands	5	5	5	1	3	5	24
Churchville Village Hall	Rain garden (Filtration)	3	3	5	2	5	5	23
Webster Empire Blvd	Bioretention (Filtration)	5	5	1	4	5	3	23
LeRoy Mill Street Parking Lot	Bioretention (Filtration)	3	3	3	3	5	5	22
Spencerport Exempt Club	Rain garden (Filtration)	1	3	3	5	5	5	22
Ogden Maida Drive	Stormwater Wetlands	5	5	3	1	1	5	20
Parma Highway Garage	Bioretention (Filtration)	3	5	3	3	5	1	20
Penn Yan Spencer Street	Stabilization (Bank)	5	5	1	1	5	3	20
Walworth Laurel Court	Stabilization (Outlet)	1	5	5	3	5	1	20
Webster Finn Park	Stormwater Wetlands	5	5	3	1	3	3	20
Churchville DPW	Bioswale (Water Qual Swale)	1	3	5	3	5	1	18
Dresden Village Center	Rain garden (Filtration)	1	1	1	5	5	5	18
Leroy Elm Street	Bioretention (Filtration)	5	3	3	1	3	3	18
Penn Yan Lakeview Cemetery	Stormwater Wetlands	3	3	5	1	1	5	18
Walworth Highway Garage	Bioswale (Water Qual Swale)	1	5	1	5	5	1	18
Penn Yan Lake Street	Bioswale (Water Qual Swale)	3	3	1	4	5	1	17
Walworth Town Hall	Porous Paving	1	3	5	2	1	5	17
Torrey Highway Garage	Bioswale (Water Qual Swale)	1	3	1	5	5	1	16
Penn Yan Spencer Street	Stabilization (Outlet)	1	5	1	2	5	1	15
Webster Friar Tuck Lane	Stormwater Wetlands	3	3	3	1	1	3	14
Penn Yan Lake Street	Bioretention (Filtration)	1	1	1	4	5	1	13

Notes:

1. For description of criteria, see GHD Technical Memorandum dated September 2, 2011.
2. Scores: Low=1, Mod=3, High=5
3. Some variable of scores are present. High-Moderate = 4 & Moderate-Low = 2
4. Totals are relative to the projects included in this study.